

Rated current of the assembly, I_{nA} : 6300 A
Date of issue: July 2020

TEST CERTIFICATE

Issued to: Elsteel (Pvt) Ltd.
Spur Road 2
Phase 1, KEPZ
Katunayake - 11420
Sri Lanka

For the product: Low-voltage switchgear and controlgear assembly

Trade name: ELSTEEL

Type/Model: 6300A Techno Module Assembly

Ratings: I_{nA} max. 6300 A, U_e max. 690 V, U_i max. 1000 V, U_{imp} max. 12 kV
 I_{cw} max. 120 kA - 1 s / 100 kA - 3 s
 I_{cc} max. 100 kA at 690 V, I_{cc} max. 100 kA at 415 V
For more details see annex

Manufactured by: Elsteel (Pvt) Ltd.
Spur Road 2
Phase 1, KEPZ
Katunayake - 11420
Sri Lanka

Subject: Design verification

Requirements: IEC 61439-2:2011
Clauses 10.2.5, 10.4, 10.5, 10.9, 10.10.2.3.5, 10.10.2.3.7a, 10.10.2.3.7c,
10.11, 10.12, 10.13, 8.101

Remarks: -

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2232107.01-INC, dated 6 July 2020.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 6 July 2020

Number: 2232107.100

DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands
T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396